



397131

8/16

Nause W WTP

Joe, Karen, Sheila

I.e. - no potential comments

↳ no problem w/ removing
surge tank

Karen

- ↳ floor
↳ doesn't have to meet OTC
secondary containment for floor
if double wall
- ↳ double wall → don't need
to do if they do a daily
inspection

→ Time for SHUTDOWN !!

→ Reinforced concrete "green tank"